

Our Ref: HL/M1402117
Test Report: M105800/B



11th September 2014

Mandals AS,
Nordre Banegt. 26,
NO-4515 Mandal,
Norway

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

HOSES & TUBING

5140

Mandals Wellman Hose. Single layer, extruded, blue coloured polyurethane hose reinforced with white coloured polyester yarn weave. For use with water up to 23°C.

APPROVAL NUMBER: 1408537
APPROVAL HOLDER: MANDALS AS

The Scheme reserves the right to review approval. This approval is valid between August 2014 and August 2019.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written over a horizontal dashed line.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme